

THE CORPORATION OF THE TOWN OF COCHRANE  
HIGHWAY 11 SOUTH WATERMAIN AND SANITARY SEWER SERVICING  
TENDER No. 2019-29

**ADDENDUM NO. 3**

ISSUED: Wednesday August 21, 2019

This addendum is issued prior to receipt of tenders and shall amend and / or clarify the work as follows:

1. Alternative methods of construction will be considered for this work including directional drilling. Relevant OPS will apply to any alternatives proposed by contractors. Bidders shall bid the work as per the Tender documents.
2. Submitting a Tender: Delete all references to submitting in envelope provided. No envelopes will be provided. Ensure that the name of the contract and the name of the bidder are clearly shown on the front cover of the bidders envelope used to submit their bid.
3. Delete pages 17 to 21 in the original Form of Tender and Part A and B from Addendum No 1 and replace with attached pages Addendum 3 pages 1 to 8.

Part B includes only the watermain works as shown on the attached Tender Part B.

Bidders may bid Part A, Part B or both. The tender deposit will reflect the bid price of Part B only.

4. The Town has in stock about 137 m of 200 mm diameter HDPE watermain piping. The Hwy 11 crossing shall be done in HDPE piping so there are no joints under the highway. If the contractor wishes to use the Town's existing HDPE piping and provide a credit for this, then please indicate that in space provided. The balance of approximately 95 m may be used elsewhere in the contract where watermain is required.
5. CAD drawings will be provided to the successful contractor prior to the start of construction.
6. Division II – Special Provisions: Section 51, Removal of Pipes and Structures. OPS 510 shall be modified that abandoned pipes shall be filled for first meter of pipe only. It is anticipated that new watermain will follow existing smaller watermain and it will be removed. Existing MH 94 has two inlets and one outlet, inlets to be rerouted to new MH2.
7. Special Provisions – Item Specific; Item 6 for Supply and Install Temporary Watermain shall be revised to require 50 mm diameter temporary waterlines. Delete reference to 150 mm diameter temporary waterlines.
8. If existing gas lines conflict with proposed new piping, the new services may be moved as required to avoid existing utilities.

End of Addendum

---

(A signed copy of this addendum is to be included in Tender submission.)

I /WE hereby acknowledge receipt of this addendum.

\_\_\_\_\_  
Signed (must be Signing Officer of Firm)

\_\_\_\_\_  
Position

\_\_\_\_\_  
Name of Firm